



C6_M **RG1**

VP	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42
Control panel	B5	B1	INPUTS				AUX				DX	TG1	Modbus RTU	B6	B7	B8	B9	OUTPUTS				FG1	S																			
230V L N B LN B GND	2x0.5 ^Ø	2x0.5 ^Ø	6x0.5 ^Ø				4x0.5 ^Ø				2x0.5 ^Ø	3x0.5 ^Ø	2x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	3x0.5 ^Ø	4x0.5 ^Ø	4x0.5 ^Ø				3x0.5 ^Ø	2x0.75 ^Ø																		
	NTC 10k	NTC 10k	Control Fire alarm Fireplace Kitchen hood Override				24V DC 0-10V output				External DX unit	Water mixing valve actuator	Modbus RTU	Supply air VAV sensor	Exhaust air VAV sensor	Air quality or humidity sensor 1	Air quality or humidity sensor 2	Common Heating Cooling Alarm				Air damper actuator	Water pump Max. load 15W																			